

01-Sep-2026 Toli Scto

Storage Location: Pharmacy of Nagasaki University Hospital

Month	Year
2026	8

Day of Month	Non Business Day	Time of reading 24-hr clock	Refrigerator 1 Logger ③			Refrigerator 2 Logger ⑤			Refrigerator 4 Logger ⑨			Refrigerator 5 Logger ⑫			Refrigerator 6 Logger ⑮			Room Logger ①			MONITORING (✓)	INITIALS
			Temperature (°C)	Alarm (✓)	No Alarm (✓)	Temperature (°C)	Alarm (✓)	No Alarm (✓)	Temperature (°C)	Alarm (✓)	No Alarm (✓)	Temperature (°C)	Alarm (✓)	No Alarm (✓)	Temperature (°C)	Alarm (✓)	No Alarm (✓)	Temperature (°C)	Alarm (✓)	No Alarm (✓)		
1	✓	___:___																				
2	✓	___:___																				
3		16:25	4.9	✓		3.2	✓		5.5	✓		3.4	✓		5.2	✓		21.8		✓	✓	S.K
4		17:00	4.5	✓		4.6	✓		5.2	✓		3.4	✓		5.5	✓		22.2		✓	✓	M.K
5		16:30	4.0	✓		3.3	✓		5.5	✓		3.4	✓		5.4	✓		22.0		✓	✓	M.K
6		16:25	5.1	✓		2.9	✓		5.5	✓		4.9	✓		4.9	✓		21.9		✓	✓	S.K
7		16:25	3.4	✓		5.1	✓		5.4	✓		4.0	✓		4.9	✓		22.2		✓	✓	M.K
8	✓	___:___																				
9	✓	___:___																				
10		16:50	4.8	✓		3.6	✓		5.1	✓		4.6	✓		5.3	✓		22.2		✓	✓	T.S
11	✓	___:___																				
12		16:20	5.1	✓		4.3	✓		5.3	✓		3.5	✓		5.0	✓		22.1		✓	✓	S.K
13		16:50	5.0	✓		4.1	✓		5.0	✓		4.9	✓		5.4	✓		22.1		✓	✓	S.K
14		11:45	5.0	✓		4.3	✓		5.2	✓		4.5	✓		5.5	✓		22.2		✓	✓	S.K
15	✓	___:___																				
16	✓	___:___																				
17		16:00	5.2	✓		3.8	✓		5.1	✓		3.4	✓		4.7	✓		21.8		✓	✓	S.K
18		16:00	5.2	✓		3.9	✓		5.0	✓		4.1	✓		5.5	✓		22.3		✓	✓	T.S
19		15:20	3.0	✓		3.0	✓		5.1	✓		3.6	✓		5.5	✓		22.4		✓	✓	T.S
20		16:20	2.8	✓		4.6	✓		5.0	✓		4.9	✓		5.0	✓		22.4		✓	✓	T.S
21		16:50	3.3	✓		3.7	✓		5.1	✓		4.9	✓		5.5	✓		22.0		✓	✓	T.S
22	✓	___:___																				
23	✓	___:___																				
24		16:25	3.1	✓		4.7	✓		5.2 ^{**}	✓		4.6	✓		5.6	✓		22.3		✓	✓	S.K
25		16:26	5.5	✓		3.7	✓		4.9	✓		4.9	✓		5.5	✓		22.3		✓	✓	S.K
26		16:20	3.0	✓		4.1	✓		4.7	✓		4.9	✓		5.6	✓		22.0		✓	✓	S.K
27		16:10	4.7	✓		2.8	✓		4.7	✓		5.0	✓		5.0	✓		22.2		✓	✓	S.K
28		16:15	4.5	✓		3.3	✓		4.7	✓		4.2	✓		5.6	✓		22.3		✓	✓	S.K
29	✓	___:___																				
30	✓	___:___																				
31		14:30	2.9	✓		4.4	✓		4.7	✓		3.9	✓		5.5	✓		22.1		✓	✓	M.K

* No records due to the public holiday

Refrigerator No.		1	2	4	5	6	INITIALS
Day of Month	Time of reading 24-hr clock	No abnormality (✓)	No abnormality (✓)	No abnormality (✓)	No abnormality (✓)	No abnormality (✓)	
21	16:50	✓	✓	✓	✓	✓	T.S

** error S.K
24 Aug 2026